

Exova Warringtonfire Aus Pty Ltd
 Unit 2, 409-411 Hammond Road
 Dandenong, Victoria 3175
 Australia

T: +61 (0)3 9767 1066
 F: +61 (0)3 9767 1001
 E: market.pacific@exova.com
 W: www.exova.com



Postal Address:
 PO Box 4282
 Dandenong South, Victoria 3164
 Australia

Testing. Advising. Assuring.

EWFA CERTIFICATE OF ASSESSMENT	CERTIFICATE No: SFC 26247-00	Page 1 of 1
---------------------------------------	-------------------------------------	--------------------

Report Sponsor	Certificate Issue Date
Australian Vinyls Corp Pty Ltd 65 Leakes Road, Laverton, VIC, 3028	27/10/2011

Introduction

This certificate confirms the element of construction described below was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced assessment report for more information.

Referenced Report	Report Issue Date	Test Standard
EWFA 26247-00	27/10/2011	AS1530.8.1-2007.



Description of Product		
Product Name	Assessed Construction	Rating
Australian Vinyls ModWood Decking	Decking Size; 137mm wide × 23mm thick Decking Gap; Nominally 4mm Subfloor Framing arrangement; Unenclosed Framing Species; Various (Refer to full report)	BAL A40

Notes

THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.

Reference should be made to the relevant assessment report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
Phone / Fax	+61 (0) 3 9767 1000 / +61 (0) 3 9767 1001	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By:  K. G. Nicholls	Reviewed By:  Steve Kettle